

W9127S-08-B-6000

RFI Question:

*Are these gel filled cables to be terminated directly to the Circa Protector Frames or should they be spliced to a non-filled cable before termination?*

Answer:

Gel filled cable PE89 (for 600-pair) shall be terminated in the splice enclosure after entering the telecommunication room prior to terminating on Circa Protector Frames. For the 50-pair and 100-pair cable, they shall be terminated directly on the Circa Protector Frames."