

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 00002	3. EFFECTIVE DATE May 8, 2009	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY Defense Distribution Center Acquisition Operations, DDC-AB J Avenue, Building 404 New Cumberland, PA 17070-5000	CODE SP3100	7. ADMINISTERED BY (If other than Item 6) Julie Metzger, 717-770-6243	CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X) 9A. AMENDMENT OF SOLICITATION NO. SP3100-09-B-5002	9B. DATED (SEE ITEM 11) Apr 10, 2009
CODE			10A. MODIFICATION OF CONTRACT/ORDER NO.	
FACILITY CODE			10B. DATED (SEE ITEM 13)	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

SEE CONTINUATION SHEET

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR	16B. UNITED STATES OF AMERICA
15C. DATE SIGNED	16C. DATE SIGNED
(Signature of person authorized to sign)	(Signature of Contracting Officer)

1. Amendment 0002 is hereby incorporated into solicitation SP3100-09-B-5002 and shall become a part of any resultant contract.
2. The following is a response to contractor submitted questions:

QUESTION 1: 1.10 In order to provide a 10 year warranty for a leveler handling 18,400 lb. gross loads and up to 15 Truckloads per day, an extremely heavy-duty dock leveler will be required. Is it acceptable to quote based on up to 8 Truckloads per day?

ANSWER 1: No

QUESTION 2: 2.7 Light Communication interior lights- can they be separate from the control box?

ANSWER 2: No

QUESTION 3: 3.2.3 Can we get an exception on the yellow & black paint? I it is expensive and does not hold up well under use.

ANSWER 3: No

QUESTION 4: 3.3.1 Roll-over tests- the Dock Leveler will be rated for 20,000 lbs. gross loads. The 28,000 lb. roll-over load will void the warranty. Can the roll-over load be changed to 20,000 lbs?

ANSWER 4: Yes

QUESTION 5: Is there a dock seal? I did not find it in the spec. If so, what is the door opening size and bumper projection?

ANSWER 5: Yes, refer to Plan Dwg C-101, sheet 2 of 6
ANSWER 6: Refer to Plan Dwg C-102, sheet 3 of 6.

QUESTION 6: Also, what is the slope to the dock? I assume it is a decline approach due to the trench drain.

ANSWER 6: Refer to Plan Dwg C-102, sheet 3 of 6.

QUESTION 7: Are any overhead doors to be replaced?

ANSWER 7: No

3. The closing date for submission of bids shall remain as **MAY 13, 2009, 2:00 PM LOCAL TIME.**

END OF AMENDMENT 0002