NORTHERN LAKE SERVICE, INC.
Analytical Laboratory and Environmental Services
400 North Lake Avenue - Crandon, WI 54520
Ph: (715)-478-2777 Fax: (715)-478-3060

ANALYTICAL REPORT

WDNR Laboratory ID No. 721026460
WDATCP Laboratory Certification No. 105-330
EPA Laboratory ID No. WI00034

Printed: 05/14/09 Code: S

NLS Project: 131068
NLS Customer: 35691

Client: **USDA/Forestry Science Lab**
Attn: Bill Danfield
5985 Highway K
Rhinelander, WI 54501

Fax: 715 362 1166 Phone: 715 362 1133

Project: **Lead & Asbestos Sampling**

Bldg 959 (Roofing Mtrl) NLS ID: 519388
COC: 96438:1 Matrix: MS
Collected: 04/28/09 11:30 Received: 04/29/09

Parameter	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Lab
Bulk asbestos	Non Detected					05/07/09	PLM	11839

Bldg 959 (Paint Chips) NLS ID: 519389
COC: 96438:2 Matrix: MS
Collected: 04/28/09 11:35 Received: 04/29/09

Parameter	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Lab
Lead, tot. recoverable as Pb by ICP	42000	mg/Kg DWB	100	260	860	05/12/09	SW846 6010	721026460
Solids, total on solids	100.0	%	1	0.10*		04/29/09	ASTM D2216	721026460
Metals digestion - tot. recov (solid) ICP	yes					05/04/09	SW846 3050M	721026460

1960 IAFS (Paint Chips) NLS ID: 519390
COC: 96438:3 Matrix: MS
Collected: 04/28/09 11:20 Received: 04/29/09

Parameter	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Lab
Lead, tot. recoverable as Pb by ICP	440	mg/Kg DWB	1	4.2	13	05/12/09	SW846 6010	721026460
Solids, total on solids	100.0	%	1	0.10*		04/29/09	ASTM D2216	721026460
Metals digestion - tot. recov (solid) ICP	yes					05/04/09	SW846 3050M	721026460

Bldg 957 (Paint Chips) NLS ID: 519391
COC: 96438:4 Matrix: MS
Collected: 04/28/09 11:15 Received: 04/29/09

Parameter	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Lab
Lead, tot. recoverable as Pb by ICP	53000	mg/Kg DWB	100	320	1000	05/12/09	SW846 6010	721026460
Solids, total on solids	100.0	%	1	0.10*		04/29/09	ASTM D2216	721026460
Metals digestion - tot. recov (solid) ICP	yes					05/04/09	SW846 3050M	721026460

Values in brackets represent results greater than or equal to the LOD but less than the LOQ and are within a region of "Less-Certain Quantitation". Results greater than or equal to the LOQ are considered to be in the region of "Certain Quantitation". LOD and/or LOQ tagged with an asterisk(*) are considered Reporting Limits. All LOD/LOQs adjusted to reflect dilution.

LOD = Limit of Detection LOQ = Limit of Quantitation ND = Not Detected (< LOD) 1000 ug/L = 1 mg/L
DWB = Dry Weight Basis NA = Not Applicable %DWB = (mg/kg DWB) / 10000
MCL = Maximum Contaminant Levels for Drinking Water Samples. Shaded results indicate >MCL.

Reviewed by:

Authorized by:
R. T. Krueger
President