GENERAL NOTES:

1. SEE PANEL SCHEDULES AND TRANSFORMER SCHEDULES FOR FEEDER SIZES.

1 ROUTE (15) 4" DIRECT BURIED EMPTY CONDUITS FROM THE SWITCHBOARD TO 5 FEET FROM THE BUILDING EDGE, IN THE DIRECTION OF UTILITY TRANSFORMER TF#9, AND CAP ALL CONDUITS.

US Army Corps of Engineers ®

MARK	DESCRIPTION	DATE
	REVISED PER AMENDMENT	19 MAY 16

ISSUE DATE: 28-APR-2016
PROJECT NO: 041449
CONTRACT NO: -
FILE NUMBER: 246

DESIGNED BY: SCH
DRAWN BY: SCH
CHECKED BY: KB
SUBMITTED BY: SCH
SIZE: ANSI 'D'
FILE NAME:

US ARMY CORPS OF ENGINEERS
NORFOLK DISTRICT
NORFOLK, VA

AIT BARRACKS COMPLEX
PHASE 3 - 600 MAN
FORT LEE, VIRGINIA

ELECTRICAL - POWER - RISER DIAGRAM

SHEET ID
VOLUME 2
EP601